

CTP1000 Space Requirements

If you use an enclosed rack for the device, ensure that there is a minimum of 3 in. of clearance between the inner side wall and the system. This clearance space ensures adequate air flow.

- Related Topics**
- CTP1000 Mechanical Requirements
 - CTP1000 Rack Requirements
 - CTP1000 Rack Installation

Published: 2010-05-11